The 7th International Forum on the Decommissioning of the Fukushima Daiichi Nuclear Power Station @Iwaki Performing Arts Center Alios

Historical challenges to understand the in-reactor and containment status of Units 1 to 3

August 28, 2023



©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved.

What is accident progression analysis method?

- High level of radioactivity inside the reactor buildings made it difficult to directly confirm the situation of the damaged reactors just after the accident.
- Understanding the in-reactor and containment status of units 1 to 3 which suffered • core damage and meltdown is crucial in decommissioning the plant.
- Thus, we started the accident progression assessment using analysis code, which • led us to assess the situation of damages inside reactors and PCV s.

Assessment using analysis code

Sufficient knowledge of the reactor design and research findings on the accident obtained so far were incorporated into analysis code, which has enabled us to assess the damage of fuel, reactors and PCVs.

As of 2011, we had reached the basic conclusion on the accident that its severity was in the order of Unit 1 > Unit 3 > Unit 2

- The actual BWR accident was unprecedented and is beyond the knowledge of technicians who have never witnessed the actual plant,
 - The analytical results using analysis code are not able to cover all the aspects of the damaged reactors, because it

etokdoesn't consider all of the structures and phenomena.

TEPCO

If we take

the past

we can

way.

into account


knowledge,

conclude this

Findings by analysis code assessment



The accident at Units 1 to 3 was due to the inability to remove decay heat, i.e. the energy from decay heat melted fuel and damaged reactors.



Elapsed days after the earthquake

Analysis code assessment is to analyze accident progression by assessing how the accumulated energy is harnessed during the period without cooling (red part).

(1)Water boiling \rightarrow Water lost

②Rise in fuel temperature

3 Chemical reaction

(heat generation/heat absorption)

④Fuel melt

(5) Heat transfer from melted fuel to structures & accompanying structure damage / melt

What is PCV internal investigation?


- As the dose on the premises and inside the R/Bs decreased gradually due to decay, TEPCO became capable of conducting hands-on investigation after 2012.
- R&D started after the accident, resulting in the development of robotics and measuring instruments. These were applied on the site and the situations inside the PCVs started to be gradually uncovered.

Hands-on observation by internal investigation

- Seeing is believing
 - Actual status including structures and phenomena which are not assessed by analysis code can be obtained as footage and dosimetry data. That means hands-on investigation is indispensable to understand the in-reactor and containment status.
- × Accessible areas are limited.
 - You cannot observe without cameras.
 - Relying on remote technology for observation creates the situation like "Blind men who touch just part of an elephant, and try to describe the whole animal".
 Thus, interpretation of what has been observed tends to become a challenge ed




ΤΞΡϹΟ





Inter-disciplinary approach between accident progression analysis and internal investigation to understand the in-reactor & PCV status

An accident progression analyst is akin to an expert on elephants who has never seen an elephant, while a person in charge of internal investigation is like someone blindfolded, compelled to deduce something solely based on their tactile experience with the elephant. They both cooperated and complemented each other, contributing to an upward spiral in the assessment




History since the accident





©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved.







©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved.

Unit 1 PCV investigation in Oct. 2012








TEPCO


Clarification of Muon investigation results at Unit 1 in 2015




Let's compare this to the simulation image of Unit 1.

©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved.

Clarification of Muon investigation results at Unit 1 in 2015 TEPCO



PCV internal investigation using a shape-changing robot at Unit 1 in March 2017



TEPCO

Information obtained from the sample analysis at Unit 1,

- Observation results of the samples as a whole
 - SEM-EDS analysis results show a mixture of U bearing particles with the rust.
 - But, the average concentration of U in the observation area (about $300\mu m \times 200\mu m$) is low and undetected.
 - ICP-MS analysis results show Fe is the largest in constituent, followed by Al, Cu, Zn, Pb, U etc.

Observation results of U particles •

Cubic crystal rich in U(U, Zr)O2, cubic crystal rich in Zr (Zr, U)O2, & monoclinic crystal ZrO2 were observed

These were also observed in the TMI-2 fuel debris. That indicates the samples experienced extremely high temperature and ZrO2 cooled down slowly, which is in line with the accident progression assumption. It is promising for future retrieval that chemically unstable U3O8 and UO3 have not been observed.

Crucial information regarding the fuel debris distribution for its retrieval in the future.


Even though the proportion is small, it indicates that U-containing materials have been found outside the pedestal. ©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved.

Cubic crystal

0.5µm

(U, Zr)02

Findings by ROV investigations at Unit 1 in 2022 to 2023 (1)



It was confirmed that the lower part of concrete was lost and rebars were exposed at the opening of the pedestal.

This is a new piece of information for accident progression analysis and its implications for the decommissioning should be considered.

Findings by ROV investigations at Unit 1 in 2022 to 2023 (2)

- The ROV couldn't reach points (\$), (9), and (10). But the footage taken at point (5) and the one taken during its movement enabled us to ascertain the base parts of pedestal. < Photo1,2>
- The observed base parts look similar to other investigation points with concrete at the lower inner part of the pedestal partially lost and rebars exposed. < Photo1,2>


The concrete has been confirmed to be lost along all circumference inside the pedestal.

©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved.

ea

PC'

PF



Findings by ROV investigations at Unit 1 in 2022 to 2023 (2) The ROV couldn't reach points (8), (9), and (10). But the footage taken at point (5) and the one taken during its movement enabled us to ascertain the base parts of ന Q pedestal. < Photo1,2> The observed base parts look similar to other investigation points with concrete at the lower inner part of the pedestal partially lost and rebars exposed. < Photo1,2> PF Rebar Inner Skirt PCV Why is it that pedestal concrete has been lost around almost its entire circumference? n23/n3/28 Why are the missing sections all Opening approximately the same height? Photo 1: Point (8) at pedestal base Point(9) Pointd Pointd¹¹ 1023/03 Photo 2: Point 9,10 and 11 0:37 at pedestal base 0:37:56

The concrete has been confirmed to be lost along all circumference inside the pedestal.

©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved.

Integrity of the pedestal at Unit 1



- Three steps are being taken, considering that the concrete has been lost at the lower part of the pedestal.
- 1. Assessment of the effects have been conducted by evaluating the strength of the inner skirt remaining in the pedestal. The result shows, even with the Mar. 2011 class earthquake, the structure will not suffer large scale collapse.

But, we shouldn't be complacent with the assessment result.

2. Assuming that the support function of the pedestal has deteriorated, a conservative scenario has been made. The result shows 0.03~0.04mSv per incident at the site boundary, which is much lower than 5mSv per incident, the criteria for accident scenarios.




Mitigation measures to be prepared in case of emergency

3. In case of loss of the supporting function, measures to prevent the radioactive dust from dispersing will be in place.


• Preparation to stop injecting nitrogen in case of emergency based on the idea that the amount of nitrogen injected should be smaller than that of exhaust for ease of controlling the dust leakage.

·Agile responses (Restoration of exhaust facilities using mobile equipment etc.)

Accident progression at Unit 2




TEPCC



19

TEPCO

Results of muon investigation conducted at Unit 2 in 2016




An investigation inside the pedestal at Unit 2 PCV using a camera robot in 2018

Pebble-like deposits spread VIEWING ANGLE 90 all over the floor inside the (mageList: pedestal. Moreover, there are a couple of places where deposits are accumulated higher than others スプリング状の VIEWING AN ImageList: mageIndex: O PF 討ての落下物の落下位置 棒状の落下物の落下位置 21


PCV

An investigation inside the pedestal at Unit 2 PCV using a camera robot in 2018






Do the higher places correspond to the locations where fuel debris dropped from above? If that's the case, the RPV is likely to have a couple of holes! The fact that a handle was found which used to be a part of the fuel assembly indicates that the scale of hole is no smaller than.....,



An investigation inside the pedestal at Unit 2 PCV using a camera robot in 2018




Deposit-contact investigation inside the pedestal at Unit 2 PCV using an improved camera robot in 2019

Can we retrieve pebble-like deposits? How about plate-like or rock-like deposits? Let's touch them using a robot!





Deposit-contact investigation inside the pedestal at Unit 2 PCV using an improved camera robot in 2019



Deposit-contact investigation inside the pedestal at Unit 2 PCV using an improved camera robot in 2019






You can pick up pebblelike or plate-like ones. Those should be retrieved as well!




Accident progression at Unit 3



TEPCO

An investigation inside the pedestal at Unit 3 PCV using an underwater ROV in 2017 (1)





An investigation inside the pedestal at Unit 3 PCV using an underwater ROV in 2017 (1)









Status of CRD housing support before the Accident at Unit 3




©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved.

An investigation inside the pedestal at Unit 3 PCV using an underwater ROV in 2017 (2)


ΤΞΡϹΟ

A cylinder-like structure (presumed CR guide tube)



An investigation inside the pedestal at Unit 3 PCV using an underwater ROV in 2017 (3)







Deposits at the bottom of the pedestal are accumulated higher towards the center.

Unit 2 PCV internal investigation & trial debris retrieval **TEPCO**

- We'll insert an arm-type device into the PCV through the X-6 penetration, remove obstacles in the PCV, and conduct internal investigation and trial retrieval.
- Several grams of fuel debris are planned to be retrieved.



Expectations for the trial retrieval of several-gram samples $T \equiv PCO$





Thank you for your attention.